

State of California
Well Completion Report
Form DWR 188 Submitted
WCR2026-001560

Owner's Well Number: GDEMW-101

Date Work Began: 01/19/2026

Date Work Ended: 02/02/2026

Local Permit Agency: Sacramento County Environmental Compliance Division

County: Sacramento

Secondary Permit Agency:

Permit Number: WP65802

Permit Date: 10/16/2025

Well Owner (must remain confidential pursuant to Water Code 13752)

Name: ---

Business Name: Sacramento Groundwater Authority

Address: 2295 Gateway Oaks Drive, STE 100

City: Sacramento State: California Zip: 95833

Planned Use and Activity

Activity: New Production or Monitoring Well

Planned Use: Monitoring

Well Location

Address: 2082 RAILROAD DR

City: SACRAMENTO Zip: 95815

Latitude: 38 Deg. 36 Min. 1.5876 Sec. N

Longitude: -121 Deg. 28 Min. 13.9836 Sec. W

Dec. Lat. : 38.600441

Dec. Long. : -121.470551

Location Accuracy:

Horizontal Datum:

Location Method:

APN: 27401900030000

Township: 09N Range: 05E

Section: 30 BM: Mount Diablo

Ground Surface Elevation:

Elevation Accuracy:

Elevation Method:

Vertical Datum:

Borehole Information

Orientation: Vertical # of casings (Specify): 1

Drilling Method: Auger Drilling Fluid: None

Total Depth of Boring: 55 (feet)

Total Depth of Completed Well: 30.5 (feet)

Water Level and Yield of Completed Well

Depth to first water:

Depth to Static Water Level:

Date Measured:

Estimated Yield*: Test Type:

Test Length*: Total Drawdown:

*May not be representative of a well's long term yield.

Geologic Log - Free Form

Depth from Surface (Feet to Feet)		Description
0	2.5	Clayey Sand, Dark Grayish Brown, Fine to Coarse Sand w/ Gravel.
2.5	17.5	Clay with Sand, Light Brownish Gray, Fine Sand Stringers
17.5	28	Clayey Sand, Dark Yellowish Brown, Fine to Medium Sand
17.5	28	Clayey Sand, Dark Yellowish Brown, Fine to Medium Sand

Depth from Surface (Feet to Feet)		Description
28	32	Silty Sand, Brown, Fine Sand w/ Trace Medium
32	55	Flowing Sand, Grayish Brown, Fine with Trace Medium

Casings										
Casing #	Depth from Surface (Feet to Feet)		Casing Type	Material	Casings Specifications	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
1	0	25	Blank	PVC	OD: 2.375 in. Thickness: 0.218 in.	0.218	2.375			Blank Well Casing
1	25	30	Screen	PVC	OD: 2.375 in. Thickness: 0.218 in.	0.218	2.375	Milled Slots	0.03	Well Screen
1	30	30.5	Blank	PVC	OD: 2.375 in. Thickness: 0.218 in.	0.218	2.375			Blank Well Casing

Annular Material					
Depth from Surface (Feet to Feet)		Fill	Fill Type Details		Filter Pack Size
0	20	Cement	Portland Cement/Neat Cement		
20	23	Bentonite	Other Bentonite		
23	30.5	Filter Pack	8 x 12		8 x 12
					SRI 8

Other Observations:

Borehole Specifications		
Depth from Surface (Feet to Feet)		Borehole Diameter (inches)
0	55	8

Certification Statement			
I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief.			
Name:	<u>WELL INDUSTRIES INC</u>		
	Person, Firm or Corporation		
<u>3282 HIGHWAY 32</u>	<u>CHICO</u>	<u>California</u>	<u>95973</u>
Address	City	State	Zip
Signed:	<u>electronic signature received</u>	<u>02/26/2026</u>	<u>812678</u>
	C-57 Licensed Water Well Contractor	Date Signed	License Number

DWR Use Only			
CSG #	State Well Number	Site Code	Local Well Number

----	----	----	N
------	------	------	---

Latitude Deg/Min/Sec

----	----	----	W
------	------	------	---

Longitude Deg/Min/Sec

APN: ----

Township: ----

Range: ----

Section: ----

Tract: ----

SEQ: ----

BM: ----

Attachments

No Attachments