

State of California
Well Completion Report
Form DWR 188 Submitted
WCR2026-001561

Owner's Well Number: GDEMW-102

Date Work Began: 01/26/2026

Date Work Ended: 02/02/2026

Local Permit Agency: Sutter County Environmental Health

County: Sutter

Secondary Permit Agency:

Permit Number: ENV2025-0122

Permit Date: 09/17/2025

Well Owner (must remain confidential pursuant to Water Code 13752)

Name: ---

Business Name: Sacramento Groundwater Authority

Address: 2295 Gateway Oaks Drive, STE 100

City: Sacramento State: California Zip: 95833

Planned Use and Activity

Activity: New Production or Monitoring Well

Planned Use: Monitoring

Well Location

Address:

City: Zip:

Latitude: 38 Deg. 54 Min. 58.0824 Sec. N

Dec. Lat. : 38.916134

Location Accuracy:

Location Method:

Longitude: -121 Deg. 34 Min. 11.01 Sec. W

Dec. Long. : -121.569725

Horizontal Datum:

APN: 33-110-067

Township: Range:

Section: BM:

Ground Surface Elevation:

Elevation Accuracy:

Elevation Method:

Vertical Datum:

Borehole Information

Orientation: Vertical # of casings (Specify): 1

Drilling Method: Auger Drilling Fluid: None

Total Depth of Boring: 45 (feet)

Total Depth of Completed Well: 40 (feet)

Water Level and Yield of Completed Well

Depth to first water:

Depth to Static Water Level:

Date Measured:

Estimated Yield*: Test Type:

Test Length*: Total Drawdown:

*May not be representative of a well's long term yield.

Geologic Log - Free Form

Depth from Surface (Feet to Feet)		Description
0	10	Silt w/ Sand, Dark Yellow Brown, Very Fine to Fine Sand
10	14	Silty Sand, Dark Yellowish Brown to Dark Brown, Fine to Medium
14	45	Flowing Sands, Dark Brown, Fine to Medium

Casings										
Casing #	Depth from Surface (Feet to Feet)		Casing Type	Material	Casings Specifications	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
1	0	25	Blank	PVC	OD: 2.375 in. Thickness: 0.218 in.	0.218	2.375			Blank Well Casing
1	25	35	Screen	PVC	OD: 2.375 in. Thickness: 0.218 in.	0.218	2.375	Milled Slots	0.03	Well Screen
1	35	40	Blank	PVC	OD: 2.375 in. Thickness: 0.218 in.	0.218	2.375			Blank Well Casing

Annular Material						
Depth from Surface (Feet to Feet)		Fill	Fill Type Details		Filter Pack Size	Description
0	20	Cement	Portland Cement/Neat Cement			Annular Seal
20	22	Bentonite	Other Bentonite			3/8" Chips
22	40	Filter Pack	8 x 12		8 x 12	SRI 8

Other Observations:

Borehole Specifications		
Depth from Surface (Feet to Feet)		Borehole Diameter (inches)
0	45	8

Certification Statement			
I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief.			
Name:	<u>WELL INDUSTRIES INC</u>		
	Person, Firm or Corporation		
<u>3282 HIGHWAY 32</u>	<u>CHICO</u>	<u>California</u>	<u>95973</u>
Address	City	State	Zip
Signed: <u>electronic signature received</u>	<u>02/26/2026</u>	<u>812678</u>	
C-57 Licensed Water Well Contractor	Date Signed	License Number	

DWR Use Only							
CSG #	State Well Number			Site Code	Local Well Number		
----	----	----	N	----	----	----	W
Latitude Deg/Min/Sec				Longitude Deg/Min/Sec			
APN: ----							
Township: ----				Range: ----			

Section: ____

Tract: ____

SEQ: ____

BM: ____

Attachments

No Attachments