

State of California
Well Completion Report
Form DWR 188 Submitted
WCR2026-001559

Owner's Well Number: SWDMW-100

Date Work Began: 01/14/2026

Date Work Ended: 02/02/2026

Local Permit Agency: Sacramento County Environmental Compliance Division

County: Sacramento

Secondary Permit Agency:

Permit Number: WP65803

Permit Date: 10/21/2025

Well Owner (must remain confidential pursuant to Water Code 13752)

Name: ---

Business Name: Sacramento Groundwater Authority

Address: 2295 Gateway Oaks Drive, STE 100

City: Sacramento State: California Zip: 95833

Planned Use and Activity

Activity: New Production or Monitoring Well

Planned Use: Monitoring

Well Location

Address: 3601 DUCKHORN DR

City: SACRAMENTO Zip: 95834

Latitude: 38 Deg. 38 Min. 2.3208 Sec. N

Longitude: -121 Deg. 31 Min. 32.4336 Sec. W

Dec. Lat. : 38.633978

Dec. Long. : -121.525676

Location Accuracy:

Horizontal Datum:

Location Method:

APN: 22501400500000

Township: 09N Range: 04E

Section: 15 BM: Mount Diablo

Ground Surface Elevation:

Elevation Accuracy:

Elevation Method:

Vertical Datum:

Borehole Information

Orientation: Vertical # of casings (Specify): 1

Drilling Method: Auger Drilling Fluid: None

Total Depth of Boring: 46.5 (feet)

Total Depth of Completed Well: 39 (feet)

Water Level and Yield of Completed Well

Depth to first water:

Depth to Static Water Level:

Date Measured:

Estimated Yield*: Test Type:

Test Length*: Total Drawdown:

*May not be representative of a well's long term yield.

Geologic Log - Free Form

Depth from Surface (Feet to Feet)		Description
0	17.5	Clay, Dark to Light Brownish Gray, Medium Plastic, Fine Sand Stringers
17.5	18	Silt, Light Olive Brown
18	20	Sandy Clay, Brown, Trace Fine Sand
20	22	Sandy Silt w/ Clay, Brown to Light Olive Brown, Trace Fine Sand

Depth from Surface (Feet to Feet)		Description
20	22	Sandy Silt w/ Clay, Brown to Light Olive Brown, Trace Fine Sand
22	37.5	Clay w/ Sand Stringers, Olive Brown, Fine to Medium Sand
37.5	40	Silt w/ Sand, Brown, Fine Sand
40	46.5	Clay, Yellowish Brown, Trace Fine Sand

Casings										
Casing #	Depth from Surface (Feet to Feet)		Casing Type	Material	Casings Specifications	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
1	0	24	Blank	PVC	OD: 2.375 in. Thickness: 0.218 in.	0.218	2.375			Blank Well Casing
1	24	34	Screen	PVC	OD: 2.375 in. Thickness: 0.218 in.	0.218	2.375	Milled Slots	0.03	Well Screen
1	34	39	Blank	PVC	OD: 2.375 in. Thickness: 0.218 in.	0.218	2.375			Blank Well Casing

Annular Material					
Depth from Surface (Feet to Feet)		Fill	Fill Type Details	Filter Pack Size	Description
0	20	Cement	Portland Cement/Neat Cement		Annular Seal
20	22	Bentonite	Other Bentonite		3/8" Chips
22	39	Filter Pack	8 x 12	8 x 12	SRI 8

Other Observations:

Borehole Specifications		
Depth from Surface (Feet to Feet)		Borehole Diameter (inches)
0	46.5	8

Certification Statement			
I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief.			
Name: <u>WELL INDUSTRIES INC</u> Person, Firm or Corporation			
<u>3282 HIGHWAY 32</u>	<u>CHICO</u>	<u>California</u>	<u>95973</u>
Address	City	State	Zip
Signed: <u>electronic signature received</u> <u>02/26/2026</u> <u>812678</u> C-57 Licensed Water Well Contractor Date Signed License Number			

DWR Use Only							
CSG #	State Well Number			Site Code	Local Well Number		
----	----	----	N	----	----	----	W
Latitude Deg/Min/Sec				Longitude Deg/Min/Sec			
APN: ----							
Township: ----				Range: ----			
Section: ----				Tract: ----			
SEQ: ----				BM: ----			

Attachments
No Attachments